

APPLICATION RATE

Soil Group (Most Limiting Layer)	Minimum Separation to Seasonal High Water Table	Absorption Area Per Bedroom	Hot Tub Rate	Soil Group (Most Limiting Layer)	Minimum Separation to Limiting Layer	Absorption Area Per Bedroom	Hot Tub Rate
2A; 2B; 2K	3 Feet	200	1.0	4N; 5I; 5L; 6A; 6E; 6G; 6K	2 Feet	385	.52
3B; 3K	3 Feet	220	.91	5J; 5M; 6C; 6H; 6L; 7A; 7D; 7F	2 Feet	445	.45
3A; 3C; 3L; 4B; 4K	3 Feet	240	.84	6I; 7E; 7G; 8A	2 Feet	500	.40
4A; 4C; 4D; 4L; 4M; 5B; 5D	3 Feet	265	.75	5N; 6J; 6M; 7I; 7K;	2 Feet	740	.27
5C; 5E; 5K; 6F	2 Feet	290	.69	7J; 7L; 8I	2 Feet	1,000	.20
5A; 5H; 6D	2 Feet	325	.62				

---

SEPTIC TANK SIZING CHART

Number of Bedrooms	Minimum Liquid Capacity	With Garbage Disposal
2 or less	750	1,125
3	1,000	1,500
4	1,250	2,000
5	1,500	2,200